

Independent, accredited testing station · Member laboratory of STL and LOVAG

TEST REPORT

NO. 1469.2101265.0692

MBS AG CLIENT

Eisbachstraße 51 74429 Sulzbach-Laufen GERMANY

Busbar systems: ERIM SRL, Novate Milanese MANUFACTURER

Distance insulators MBS AG

Busbar systems for low-voltage switchgear assemblies TEST OBJECT

with distance insulators

DB/P 50 with M10 & M12 threads TYPE:

SERIAL NO. Test sample RATED CHAR-Rated operational voltage 400 V **ACTERISTICS GIVEN** Rated insulation voltage 1000 V U_{i} BY THE CLIENT Rated peak withstand current: 63 kA 30 mm x 10 mm up to 40 mm x 10 mm up to 106 kA 60 mm x 10 mm up to 132 kA 80 mm x 10 mm up to 144 kA Rated frequency 50 Hz

IEC 61439-2: 2009-01, EN 61439-2: 2009-11

NORMATIVE DOCUMENT

Verification of dynamic short-circuit withstand strength RANGE OF TESTS PERFORMED

12 to 14 October 2010 DATE OF TEST

See Sub-clause 4.6 TEST RESULT

RONALD BORCHERT

Senior engineer Test engineer in charge

Berlin, 25 November 2010



